FREQUENTLY ASKED QUESTIONS About Bidding a Project

Q. Where can I find information about Bid No. REBID B20/21-07?

A. Information will be made available on the District's website. To access the site go to http://www.clpccd.org/business/open.php Under Bidding Opportunities, Invitation to Bid, find the applicable project – Bid No. REBID 20/21-07.

Q. What is the scope for this project?

A. The scope of the project includes providing a booster pump system to raise the campus domestic water pressure. Pressure reducing valves will be installed at selected buildings to prevent overpressure of plumbing fixtures. As an alternate, the contractor shall install an AquaShield enclosure (or approved equivalent product) around the booster pump station. The enclosure shall have a mill grade marine aluminum or stainless steel finish. The enclosure must also be fitted with a removable top and access doors on its front, side and rear.

Q. What is the Engineering Estimate for this project?

A. The estimate for the Las Positas College-Domestic Water Booster System Project is **\$450,000** which includes the alternate.

Q. What does the bid document consist of?

A. The bid document consists of District's Div. 00 and 01; and Sandis technical specifications, and drawings for the project.

Q. Where can I obtain a set of plans for this project?

A. http://www.clpccd.org/business/open.php

Q. Where do I send my questions regarding the bid documents?

A. Using the "Bid Question Form" which was handed out at the Pre-Bid Site Visit or can be obtained from the District's website (see above to find site). Email to Michael McClung at mmcclung@clpccd.org and Marie Hampton at mhampton@clpccd.org

Q. Will there be a MANDATORY WALK for this project?

A. Yes. General Contractors are **REQUIRED** to attend the Pre-Conference and Job Walk on **Monday, March 29, 2021 at 10:00 AM.** All participants are required to sign-in at the Pre-Bid Conference and Job Walk and provide business cards including e-mail address. Bidders are to meet at Las Positas College campus at 3000 Campus Hill Drive., Facilities Management Office Trailer adjacent to building 1300, Livermore, California 94551. Failure to attend or tardiness will render bid ineligible.

Q. Where can I get a copy of the Pre-Bid Conference Sign-in Sheet or the plan holders list?

A. Job Walk attendees and Plan holder's List can be found at: http://www.clpccd.org/business/open.php

Q. Is this project subject to a Project Labor Agreement (PLA)?

A. No.

Q. Does the General Contractor have to be pre-qualified with your District in order to bid this project?

A. No.